

WINDING STAIRS

UNIFORM BUILDING CODE 1003.3.3.8.2

THE FOLLOWING DETAIL IS FOR THE INSTALLATION OF WINDING STAIRS IN RESIDENTIAL SINGLE FAMILY (R3), DUPLEX (R3), AND THE INTERIOR OF INDIVIDUAL DWELLING UNITS OF MULTIFAMILY BUILDINGS (R1).

NOTE THE FOLLOWING ARE REQUIRED:

MINIMUM 36" CLEAR STAIR WIDTH

A HANDRAIL IN ACCORDANCE WITH UBC 1003.3.3.6

A GUARDRAIL IN ACCORDANCE WITH UBC 509

TREADS:

MIN. 6" RUN AT NARROWEST SIDE

MIN. 9" RUN 12' FROM NARROWEST SIDE

RISERS:

MIN. 4"

MAX 8"

